

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>000080</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b> B. WING _____	(X3) DATE SURVEY COMPLETED  <b>08/24/2012</b>
NAME OF PROVIDER OR SUPPLIER  <b>STONEBROOKE REHABILITATION CENTRE &amp; SUITES</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>990 N 16TH ST NEW CASTLE, IN 47362</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 08/24/12</p> <p>Facility Number: 000080 Provider Number: 155160 AIM Number: 100289330</p> <p>Surveyor: Mark Bugni, Life Safety Code Specialist</p> <p>At this Quality Assurance Walk-thru survey, Stonebrooke Rehabilitation Centre &amp; Suites was found in compliance with 410 IAC 16.2-3.1-19(ff).</p> <p>This two story facility was determined to be of Type II (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection on all levels including the corridors, spaces open to the corridors and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 152 and had a census of 87 at the time of this visit.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p> <p>Quality Review by Robert Booher, REHS, Life Safety Code Specialist-Medical Surveyor on 08/30/12.</p>	S 000		

Indiana State Department of Health

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

6899

N5DU21

If continuation sheet 1 of 1